

MONTHLY FIRE SAFETY INSPECTION FORM

Facility				Inspector		
Location		D = -		Date		
FACILITIES FIRE PROTECTION SYSTEMS. COMPLETE THE C	D, TES HECK SPECT	STEI LIST	O, AND IN ACC	INSTRUCTIONS: MAINTAINED TO HELP ENSURE COMPLETE AND TOTAL RELIABILI CORDANCE WITH THE FREQUENCY RECOMMENDED. DO NOT COI STED THAT PARTICULAR PIECE OF FIRE PROTECTION EQUIPMENT CHARGE FOR NECESSARY ACTION.	MPLETE A	Α.
			_	NERAL INFORMATION NEEDED TO COMPLY WITH MOST AS A SUBSTITUTE FOR ANY ADVICE PROVIDED BY Y		
INSPE	CT 1	ГΗΙ	ESE	ITEMS AT LEAST MONTHLY		
I	MAN	IU.	AL P	ROTECTION		
	Yes	S	No		Yes	No
ADEQUATE NUMBER OF FIRE EXTINGUISHERS				MANUAL PULL STATIONS TESTED PERIODICALLY		
PROPER EXTINGUISHERS FOR OCCUPANCY				INSIDE HOSES ACCESSIBLE		
EXTINGUISHERS PROPERLY CHARGED				INSIDE HOSES IN GOOD CONDITION		
EXTINGUISHERS PROPERLY LOCATED AND PLACED (HUNG ON SUPPORTS)				PRIVATE YARD HYDRANTS ACCESSIBLE AND IN GOOD CONDITION		
GENERAL COMMENTS: GENERAL (CON	IDI	TIOI	NS/ SPECIAL HAZARDS		
	Yes	S	No		Yes	No
GOOD HOUSEKEEPING NOTED THROUGHOUT				MECHANICAL VENTILATION SYSTEMS OPERATING		
MINIMAL AISLE STORAGE NOTED IN WHSE. AREAS				AEROSOLS KEPT IN METAL CABINETS		
SMOKING REGULATIONS ENFORCED WITH SIGNS POSTED THROUGHOUT				COMPRESSED CYLINDERS PROPERLY STORED AND CHAINED		
STORAGE SKIDDED OFF FLOOR				IDLE PALLET STORAGE BELOW 6 FT.		
STORAGE WELL ARRANGED TO PREVENT COLLAPSE				ELECTRICAL EQUIPMENT IN GOOD CONDITION		
COMBUSTIBLE WASTE REMOVED PROMPTLY				HEATING SYSTEM IN GOOD CONDITION		
COMBUSTIBLES COMPLETELY REMOVED FROM COMPUTER /ELECTRICAL/MECHANICAL ROOMS				PROCESS FUEL-FIRED EQUIPMENT IN GOOD CONDITION		
DUST/LINT OR OILY DEPOSITS REMOVED FROM CEILINGS, BEAMS OR EQUIPMENT				OUTSIDE YARD STORAGE ADEQUATELY SEPARATED FROM BUILDING		
FLAMMABLE LIQUID DISPENSING CONTAINERS PROPERLY GROUNDED				ADEQUATE PROTECTION AGAINST THEFT AND VANDALISM		
FLAMMABLE LIQUID DISPENSING CONTAINERS PROVIDED WITH SAFETY RELIEF BUNGS				BUILDING ROOF CONSTRUCTION IN GOOD CONDITION		
FLAMMABLE LIQUID DISPENSING CONTAINERS PROVIDED WITH SELF CLOSING FAUCETS				BUILDING ROOF FREE FROM PONDING OR LEAKAGE		
FLAMMABLE LIQUIDS KEPT IN METAL CABINETS OR PROPERLY DESIGNED ROOM				DOMESTIC VALVES AND PIPES PROPERLY LABELED AND TAGGED		
GENERAL COMMENTS: Additional Comments:						